

RECEIVED TOWN CLERK CRAFTON, MA

Katrina Koshivos <koshivosk@grafton-ma.gov>

9 Millbury Street

1 message

2022 HAY 26 | AM 8: 52

Michael Killeen <killeenm@grafton-ma.gov>
To: Zoning Department <zba@grafton-ma.gov>

Wed, May 25, 2022 at 2:14 PM

Good afternoon,

The Fire Department would like to provide a reminder that an addition or modification that occurs to a home after 2008 may require heat alarms in the added garage, and/or a hardwired smoke detector system within the residence. Thank you.

Captain Michael Killeen Fire Prevention Officer Grafton Fire Department RECEIVED

MAY 26 2022

Zoning Board of Appeals